USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Reclamation

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

RECEIVED DEC 10 Department of Reclamation

1. WELL OWNER

Name FRED GOODING

Address ROUTE 2 WILDER IDAHO

Owner's Permit No.

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test

☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

☒ Cable ☐ Rotory ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 185 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
.250 inches	6 inches	0 feet	150 feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet
inches	inches	feet	feet

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☐ Yes ☒ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation inches by inches

Number	From	To
perforations	feet	feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name

Type Model No.

Diameter Slot size Set from feet to feet

Diameter Slot size Set from feet to feet

Gravel packed? ☐ Yes ☒ No Size of gravel


Placed from feet to feet

Surface seal? ☒ Yes ☐ No To what depth 18 feet

Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.



6 M

County CANYON

NE ¼ SE ¼ Sec. 21, T. 4 N, R. 5 W

7. WATER LEVEL

Static water level 80 feet below land surface

Flowing? ☐ Yes ☒ No G.P.M. flow

Temperature ° F. Quality GOOD

Artesian closed-in pressure p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☒ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
10	20	1

31509

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6	0	2	TOPSOIL		
	2	28	GRAVEL		
	28	40	BLACK SAND		
	40	60	BROWN CLAY		
	60	90	BROWN SAND		
	90	121	SANDY BROWN CLAY		
	121	145	CAVING BROWN CLAY		
	145	170	BROWN CLAY		
	170	185	BLUE CLAY		
	185		SMALL BLACK GRAVEL		

10.

Work started NOV. 16-69 finished NOV. 26-69

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

METZER WELL DRILLING 93
Driller's or Firm's Name Number

HOMEDALE IDAHO
Address

Kenneth L. Metzer NOV. 28-69
Signed By Date

USE ADDITIONAL SHEETS IF NECESSARY