

RECEIVED
JUN 12 1967

REPORT OF WELL DRILLER
State of Idaho

Department of Reclamation

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name Mr Van Warren

Address #66
Caldwell Idaho

Owner's Permit No. _____

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: Domestic

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒

Dug ☐ Other _____

(explain)

CASING SCHEDULE: Threaded _____ Welded _____

6 "Diam. from ft. above ft. to 70 ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

Thickness of casing: 2.50 Material:

Steel ☒ concrete ☐ wood ☐ other ☐

(explain)

PERFORATED? Yes ☐ No ☒ Type of perforator used: _____

Size of perforations: _____ " by _____ "

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

WAS SCREEN INSTALLED? Yes ☐ No ☐

Manufacturer's name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☐ size of gravel _____ Gravel

placed from _____ ft. to _____ ft. Surface seal

provided? Yes ☐ No ☐ To what depth?

_____ ft. Material used in seal: _____

Did any strata contain unusable water? Yes ☐

No. ☒ Type of water: _____


Depth of strata _____ ft. Method of sealing

strata off: _____

Surface casing used? Yes ☐ No. ☒

Cemented in place? Yes ☐ No ☐

Locate well in section



LOCATION OF WELL: County Canyon

SE 1/4 SE 1/4 Sec. 22 T. 4 N. R. 4 W

Size of drilled hole: 6 " Total

depth of well: 75 Standing water

level below ground: 15 Temp.

Fahr. _____ ° Test delivery: 100 gpm

or _____ cfs Pump? ☒ Bail ☐

Size of pump and motor used to make test:

285 C.F.M. air compressor

Length of time of test: _____ Hrs. _____ Min.

Drawdown: _____ ft. Artesian pressure: ft.

above land surface _____ Give flow _____ cfs

or _____ gpm. Shutoff pressure:

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☐

DEPTH MATERIAL **31607** WATER

FROM TO YES OR NO

FEET FEET

0 5 Top soil & hard pan no

5 35 sandy clay no

35 53 sand & gravel yes

53 65 sandy shale no

65 73 shale no

73 88 sand & hard shale strata yes

88 ? shale no

Use other side for additional remarks

U.S.D.