

RECEIVED
AUG 29 1960

Department of Reclamation

WELL LOG AND REPORT OF THE
STATE RECLAMATION ENGINEER OF IDAHO

Permit No. _____ Well No. _____ County Canyon
Owner S. S. Steiner Co.
Address Box 964 Caldwell Idaho
Driller William E. Doty
Address Box One Box 1-085 Nampa
Well location NW 1/4 SE 1/4 Sec. 28, T. 4 N. R. 4 W
Size of drilled hole 6"

034942

Locate well in section

NW 1/4	NE 1/4
SW 1/4	SE 1/4

22
0

Total depth of well 54'-6"

Give depth to standing water from the ground _____ Water temp. _____ °Fahr.

On "Pumping Test" delivery was 100 g.p.m. or _____ c.f.s. Drawdown was 20 feet.Size of pump and motor used to make test 285 CF air compressorLength of time of test 2 hours _____ minutes.If flowing well, give flow _____ c.f.s. or 45 g.p.m. and of shut off pressure _____

If flowing well, described control works _____

Water will be used for Domestic & Fire protection (TYPE AND SIZE OF VALVE, ETC.)
Weight of casing per lineal foot 20 #Thickness of casing 1/4 Casing material Steel
(STEEL, CONCRETE, WOOD, ETC.)Diameter, length and location of casing 6" 23'-6" H.L. to 23'-6"
(CASING 12" IN DIAMETER OR LESS, GIVE INSIDE DIAMETER;
CASING OVER 12" IN DIAMETER, GIVE OUTSIDE DIAMETER)below ground level

CASING RECORD

Diam. Casing	From Feet	To Feet	Length	Remarks—seals, grouting, etc.
6	0	23'-6"	23'-6"	

Number and size of perforations _____ located _____ feet to _____ feet from ground

Date of commencement of well May 30 1960 Date of completion of well June 1, 1960

NW SE 5.22 4N 4W

WELL LOG

[illegible]

WELL DRILLER'S STATEMENT

This well was drilled under my supervision and the above information is true and correct to the best of my knowledge and belief.

Signed Jesse J. Doty
By William E. Doty

Dated July 25, 1960.

License No. 159