

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT


Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 63-95-W-0125-000 ²⁰⁰
Other IDWR No. 63-03608

2. OWNER: City of Nampa 1A
Name City of Nampa
Address 1450 S 3rd
City Nampa State OR Zip 97913

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 6 North or South
Rge. 5 East or West
Sec. 7 1/4 NE 1/4 NE 1/4
Gov't Lot 1 County Canyon

Address of Well Site East Bank of Snake River
City Nampa

Lt. _____ Blk. _____ Sub. Name _____

4. PROPOSED USE:

- Domestic Municipal Monitor Irrigation
 Thermal Injection Other _____

5. TYPE OF WORK

- New Well Modify or Repair Replacement Abandonment

6. DRILL METHOD

- Mud Rotary Air Rotary Cable Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
Cement	0	20	1892	Overbore
10-9 Silica	10	58	4289	Pressure Grout

Was drive shoe used? Y N Shoe Depth(s) 20'
Was drive shoe seal tested? Y N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
20	1	20	3/8	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10	2	54	3/8	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe 34 Length of Tailpipe 10

9. PERFORATIONS/SCREENS

- Perforations Method _____
 Screens Screen Type 304 Stainless Welded

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
34	44	.080		10	Stainless	<input checked="" type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

11 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS: **49117**

- Pump Bailer Air Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>Pump 275</u>	<u>33'</u>		<u>18 hr</u>
<u>Air 300</u>	<u>54'</u>		

Water Temp. 61° Bottom hole temp. _____
Water Quality test or comments: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
	0	8	Brown Silty Clay		
	8	20	Sand & Gravel	X	
	20	44	Sand & Gravel	X	
	44	58	Blue Clay		

RECEIVED
AUG 07 1995
Department of Water Resources

RECEIVED
JUL 28 1995
WATER RESOURCES
WESTERN REGION
late pm

Completed Depth 54 (Measurable)
Date Started 5-13-95 Completed 6-16-95

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Dallas Drilling Firm No. 445
Firm Official [Signature] Date 7-25-95
and
Supervisor or Operator _____ Date _____

(Sign once if Firm Official & Operator)