

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen


49119

1. DRILLING PERMIT NO. 63-95-W-0129-200 Other IDWR No. 63-03608

2. OWNER: City of Nappa 4A Name 14 SW 3rd Address City Nappa State OR Zip 97913

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 6 North or South Rge. 5 East or West Sec. 7 1/4 NE 1/4 NE 1/4 Gov't Lot 1 County Canyon

Address of Well Site East Bank of Snake River City Nappa

Lt. Blk. Sub. Name

4. PROPOSED USE:

- Domestic, Municipal, Monitor, Irrigation, Thermal, Injection, Other

5. TYPE OF WORK

- New Well, Modify or Repair, Replacement, Abandonment

6. DRILL METHOD

- Mud Rotary, Air Rotary, Cable, Other

7. SEALING PROCEDURES

Table with columns: SEAL/FILTER PACK (Material, From, To), AMOUNT (Sacks or Pounds), METHOD. Includes entries for Cement, G-95 SILICA, and BENTONITE.

Was drive shoe used? Y N Shoe Depth(s) 20 Was drive shoe seal tested? Y N How?

8. CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Material, Casing, Liner, Welded, Threaded. Includes entries for 20 inch and 10 inch diameters.

Length of Headpipe 28 Length of Tailpipe 11

9. PERFORATIONS/SCREENS

- Perforations, Method, Screens, Screen Type 304 Stainless Welded

Table with columns: From, To, Slot Size, Number, Diameter, Material, Casing, Liner. Includes entry for 28 to 38 inch diameter with .080 slot size.

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

11 ft. below ground Artesian pressure lb. Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

- Pump, Bailer, Air, Flowing Artesian

Table with columns: Yield gal./min., Drawdown, Pumping Level, Time. Includes entries for Pump 225 and AIR 300.

Water Temp. 61 Bottom hole temp.

Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Lithologic log table with columns: Bore Dia., From, To, Remarks: Lithology, Water Quality & Temperature, Y, N. Includes entries for Braun Silty Clay, Sand and Gravel, Blue Clay, and Black and White Sand.

RECEIVED AUG 07 1995

Department of Water Resources

RECEIVED

JUL 28 1995

WATER RESOURCES WESTERN REGION

Completed Depth 47 (Measurable) Date: Started 5-11-95 Completed 6-16-95

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Dallas Drilling & Pump Firm No. 445 Firm Official Date 7-25-95 and Supervisor or Operator Date

(Sign once if Firm Official & Operator)