Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

053836

Office Use Only
Inspected by _____
Twp ____ Rge ____ Sec ____
____ 1/4 ____ 1/4 ____ 1/4
Lat: : : Long: : :

1. WELL TAG NO. D 000 9608
DRILLING PERMIT NO. 63-99-W 0423-000
Other IDWR No. _____

2. OWNER:
Name MARK GAVIOLA
Address 20260 FARGO RD.
City WILDER State ID Zip 83676

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 4 North ■ or South ☐
Rge. 5 East ☐ or West ■
Sec. 22, ____ 1/4 NW 1/4 SW 1/4 (10 acres / 40 acres / 160 acres)
Gov't Lot ____ County CANYON
Lat: : : Long: : :
Address of Well Site 20260 FARGO RD
(Give at least name of road + Distance to Road or Landmark)
City WILDER

Lt. _____ Blk. _____ Sub. Name _____

4. USE:
■ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
■ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☐ Air Rotary ■ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	18	8	GROUT

Was drive shoe used? ■ Y ☐ N Shoe Depth(s) _____
Was drive shoe seal tested? ■ Y ☐ N How? BAILED

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	127	250	STEEL	■	☐	■	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
Perforations Method _____
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
70 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:
☐ Pump ☐ Bailer ■ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
25	20'	130	4 HRS.

Water Temp. 60° Bottom hole temp. _____
Water Quality test or comments: 18 GRNS, .05 IRON
Depth first Water Encounter _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
6	0	6	SANDY BROWN CLAY		—
	6	14	GRAVEL HARD		—
	14	29	BROWN SAND		→
	29	40	GRAVEL		—
	40	87	BROWN SAND		→
	87	95	SAND-GRAVEL LITTLE	—	
	95	112	BROWN CLAY		—
	112	124	SANDY BLUE CLAY		—
	124	147	BLUE CLAY		—
	147		BLACK SAND & GRAVEL	—	

RECEIVED
JUL 13 1999
Department of Water Resources

RECEIVED
JUL 09 1999
WATER RESOURCES
WESTERN REGION

MICROFILMED
OCT 13 1999

Completed Depth 147 (Measurable)
Date: Started 6-8-99 Completed 6-11-99

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name KENNE METZER DRL, Firm No. 93
Firm Official Kenne Metz Date 6-30-99
and
Driller or Operator Kenne Metz Date 6-30-99
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES