

# WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

**1. WELL OWNER**  
 Name Bill & Diane Beagle  
 Address Route 2, Box 301D, Old Town, ID  
 Drilling Permit No. 96-92-N-134  
 Water Right Permit No. \_\_\_\_\_

**7. WATER LEVEL**  
 Static water level 80 feet below land surface.  
 Flowing?  Yes  No G.P.M. flow \_\_\_\_\_  
 Artesian closed-in pressure \_\_\_\_\_ p.s.i.  
 Controlled by:  Valve  Cap  Plug  
 Temperature \_\_\_\_\_ °F. Quality \_\_\_\_\_  
 Describe artesian or temperature zones below.

**2. NATURE OF WORK**  
 New well  Deepened  Replacement  
 Well diameter increase  
 Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

**8. WELL TEST DATA**  
 Pump  Bailer  Air  Other \_\_\_\_\_

Discharge G.P.M.	Pumping Level	Hours Pumped
20+ GPM Estimated	air lift	

**3. PROPOSED USE**  
 Domestic  Irrigation  Test  Municipal  
 Industrial  Stock  Waste Disposal or Injection  
 Other \_\_\_\_\_ (specify type)

**9. LITHOLOGIC LOG** 081950

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
8"	0	5	Sandy		X
8"	5	7	Gravel		X
8"	7	20	Sand & gravel		X
6"	20	55	Gravel & cobbles		X
6"	55	74	Clay tan		X
6"	74	115	Sand semi coarse	X	
6"	115	120	Sand coarse	X	

**4. METHOD DRILLED**  
 Rotary  Air  Hydraulic  Reverse rotary  
 Cable  Dug  Other \_\_\_\_\_

**5. WELL CONSTRUCTION**  
 Casing schedule:  Steel  Concrete  Other \_\_\_\_\_



Thickness	Diameter	From	To
.250 inches	6 inches	+ 2 feet	114 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used?  Yes  No  
 Was a packer or seal used?  Yes  No  
 Perforated?  Yes  No  
 How perforated?  Factory  Knife  Torch  Gun  
 Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed?  Yes  No  
 Manufacturer's name Johnson Stainless steel  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diameter 5" Slot size 10 Set from 114 feet to 119 feet  
 Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Gravel packed?  Yes  No  Size of gravel \_\_\_\_\_  
 Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface seal depth 20 Material used in seal:  Cement grout  
 Bentonite  Puddling clay  \_\_\_\_\_  
 Sealing procedure used:  Slurry pit  Temp. surface casing  
 Overbore to seal depth  
 Method of joining casing:  Threaded  Welded  Solvent Weld  
 Cemented between strata

Describe access port \_\_\_\_\_



**6. LOCATION OF WELL**  
 Sketch map location must agree with written location.

N			
W		X	E
			S

Subdivision Name \_\_\_\_\_  
 Lot No. \_\_\_\_\_ Block No. \_\_\_\_\_  
 County Bonner county  
 NW ¼ SE ¼ Sec. 31, T. 56 N  E   
 S  R. 5 W

**10.** Work started 7-30-92 finished 7-31-92

**11. DRILLERS CERTIFICATION**  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
 Firm Name Ponderosa Drilling Firm No. 228  
 Address E. 6010 Braodway Date 8-3-92  
 Signed by (Firm Official) W. Scott Barratt  
 and (Operator) Greg Klundt  
 (Greg Klundt)