

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR DRILLING PERMIT

1. Name: DAVID WALKER

O 208-793-2266

Address: PO BOX 179

HORSESHOE BEND ID 83629

2. Proposed Well Location: Township 10N, Range 01E, Sec. 14, SESE
BOISE County

Lot, Block, and Subdivision: Lt 10

Blk 2

GARDEN VALLEY ESTATES

RECEIVED

JAN 06 1995

WATER RESOURCES
WESTERN REGION

3. Proposed Use of Well: Domestic

The use of water for homes, organization camps, livestock and for any other purpose in connection therewith, including irrigation for up to .5 acres of land, if the total use is not in excess of 13,000 gpd; or any other uses, if the total use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

Domestic does not include water for multiple ownership subdivisions, mobile home parks, commercial or business establishments, unless the use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

4. Well Construction Information:

A. Deepen

B. Proposed Surface Diameter 6 In. Proposed Maximum Depth 200 Ft.

C. Anticipated Bottom Hole Temperature: 85 F or less (Cold water well)

(NOTE: Construction diagrams and/or other information may be requested for monitor, low temperature geothermal, municipal and artesian wells.)

5. Construction Start Date: 10/17/1994

6. Anticipated Well Driller: ROCKY MOUNTAIN DRILLING (No. 0211)

NOTE: The actual well driller must be identified prior to drilling.

7. Applicant's Signature David Walker Date 1-4-95Title Driller
(Owner, Firm Representative, Other)*****
Fee \$ 560 Received by Ruby No. C031927 Date 1/4/95

(Continued)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This verbal permit issued on 10/17/1994 by _____

NOTE:

This permit was authorized based on a verbal conversation or other information provided by the driller. If this information is incorrect, the driller is responsible for notifying the proper IDWR Office with the correct information.

This final permit is Approved

Date: 1-4-95

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. READ CAREFULLY!

CONDITIONS OF APPROVAL:

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare which may be required prior to construction of this well. The local Health Department should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100' from any drainfield and 50' from any septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
7. If the bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
8. The use of water from this well is for Domestic purposes only which includes irrigation of up to 1/2 acre of land with all combined uses not to exceed 13,000 gallons per day (42-111[A]), or for Domestic uses other than for homes, organization camps, public campgrounds or livestock where the diversion rate and volume does not exceed .04 cfs and 2500 gpd (42-111[B]).

Mark B. Stiff
Signature of Authorized Dept. Representative

Sec. Manager
Title

EXTENSION OF DRILLING PERMIT

Extension Approved by: _____

Approval Date: _____

Expires On: _____