

C
STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR DRILLING PERMIT

1. Name: GARY DUTTON O 208-466-0154
Address: 17762 LEWIS LN
CALDWELL ID 83605

Name: BOBBY DUTTON O 208-466-0154
Address: 17762 LEWIS LN
CALDWELL ID 83605

2. Proposed Well Location: Township 02N, Range 03W, Sec. 7, NESW
CANYON County

Street Address of Well Site: SAME

ID

3. Proposed Use of Well: Injection

4. Well Construction Information:

- A. New Well
B. Proposed Surface Diameter 6 In. Proposed Maximum Depth 140 Ft.
C. Anticipated Bottom Hole Temperature: 85 F or less (Cold water well)
(NOTE: Construction diagrams and/or other information may be requested for
monitor, low temperature geothermal, municipal and artesian wells.)

5. Construction Start Date: 3/ 9/1995

6. Anticipated Well Driller: ADAMSON PUMP & DRILLING (No. 0457)
NOTE: The actual well driller must be identified prior to drilling.

7. Applicant's Signature Bobby K. Dutton Date 3-8-95
Title _____
(Owner, Firm Representative, Other)

Fee \$ 35- Received by CJD No. W018704 Date 3/8/95

(Continued)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This permit is APPROVED

Date: 3/ 8/1995

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. READ CAREFULLY!

CONDITIONS OF APPROVAL:

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare which may be required prior to construction of this well. The local Health Department should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100' from any drainfield and 50' from any septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
7. If the bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (Dig Line is a locator service) not less than 3 working days prior to the start of any excavation for this project. The "Dig Line " Number for your area is 1-800-342-1585.
9. Injection may not occur into this well until permit to inject no. 63-W-0116 has been approved.

Cindy Hodges for
DAVID R. TUTHILL JR.

Signature of Authorized Dept. Representative

MANAGER

WESTERN REGIONAL OFFICE

Title

EXTENSION OF DRILLING PERMIT

Extension Approved by: _____

Approval Date: _____

Expires On: _____