

# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 72154  
 Drilling Permit No 880457  
 Water right or injection well # \_\_\_\_\_

2. OWNER:  
 Name George Schreyer  
 Address 2150 Samuels Rd  
 City Sandpoint State ID Zip 83864

3. WELL LOCATION:  
 Twp 59N North  or South  Rge 1 East  or West   
 Sec 34 1/4 SE 1/4 NW 1/4  
 Gov't Lot \_\_\_\_\_ County Bonner  
 Lat N 48° 25.513 (Deg and Decimal minutes)  
 Long. W 116° 27.183 (Deg and Decimal minutes)  
 Address of Well Site 2150 Samuels Rd. (Big Wind Mill in Field) City Samuels

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:  
 New well  Replacement well  Modify existing well Deepen  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>N/A</u>				

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>6" + 1"</u>	<u>61</u>	<u>existing pipe</u>			<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) ?

9. PERFORATIONS/SCREENS:  
 Perforations  Y  N Method \_\_\_\_\_  
 Manufactured screen  Y  N Type Stainless Steel Tonger  
 Method of installation removed old screen, install New one

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
<u>58</u>	<u>98</u>	<u>4</u>		<u>5"</u>	<u>S.S.</u>	<u>Tele. 304</u>

Length of Headpipe 2' Length of Tailpipe 0  
 Packer  Y  N Type "K"

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

11. FLOWING ARTESIAN:  
 Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
 Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:  
 Depth first water encountered (ft) 61 Static water level (ft) 15'  
 Water temp (°F) 42 Bottom hole temp (°F) 42  
 Describe access port Well Seal

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
<u>80'</u>	<u>55 gpm</u>	<u>29 hrs</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: Clear Clean.

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>8"</u>	<u>60</u>	<u>98</u>	<u>Sand</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>8"</u>	<u>98</u>	<u>100</u>	<u>Sandy clay</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

existing screen on well plugged with mineral scale - and water production dropped removed and deepened well to bottom of water bearing zone. Screen entire water course as per customer request. Casing setting at exact previous depth.

**RECEIVED**  
**OCT 21 2016**  
**IDWR / NORTH**

208-263-5974

Mark Pitts  
Robin Pitts

*Serving North Idaho Over 20 Years*



**DRILLING • PUMPS • WATER TREATMENT**  
 Complete Systems • From the Well To The House  
 435 Woodview Rd. • Sandpoint, ID 83864

Completed Depth (Measurable): 98'

Date Started 9-29-16 Date Completed 10-20-16

14. DRILLER'S CERTIFICATION:  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
 Company Name AAA Sweetwater Drilling Inc Co No 509  
 \*Principal Driller Mark Pitts Date 10-20-16  
 \*Driller \_\_\_\_\_ Date \_\_\_\_\_  
 \*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.