

RECEIVED

JUN 15 2022

WATER RESOURCES
WESTERN REGION

63

Form 235-1
03/2018

Drilling Permit No. 905735

Drilling Permit I.D. Tag No. D-0097234

Water Right Permit No.

Injection Permit No.

43° 40.230
- 116° 47.514State of Idaho
Department of Water Resources
APPLICATION FOR DRILLING PERMIT
(FOR THE CONSTRUCTION OF A WELL)See
Specific
Conditions

1. Property Owner (please print): CAPITAL SHEET METAL

2. Current Mailing Address: 18155 GRAND AVE

City: LAKE ELSINORE State: CA Zip Code: 92530 Telephone: (951) 678-2000

3. Proposed Well Location: Township 4N Range 4W Section 23 1/4 S/W 1/4 N/W

Gov't Lot No. County CANYON Lat. 43.6705 approx Long. -116.7919 approx

Street Address of Well Location 19971 MONTE WAY City CALDWELL

If an address is unavailable, list the road + the distance to nearest crossroad or landmark.

Lot, block, & subdivision MUNN RANCH LOT 4 BLK 3

4. Proposed Use of Well: (Note: Any well drilled for a Public Water Supply requires prior DEQ approval.)

☐ DOMESTIC (42-111a): The use of water for homes, organization camps, public campgrounds, livestock and for any other purpose in connection therewith, including irrigation of up to 1/2 acre of land, if the total use is not in excess of 13,000 gpd.☒ DOMESTIC (42-111b): Any other use if the diversion rate does not exceed 0.04 cfs (18 gpm) and a diversion volume of 2500 gpd.NON-DOMESTIC: ☐ Irrigation ☐ Commercial ☐ Municipal ☐ Other (Describe) ☐ Industrial ☐ Public Water Supply☐ INJECTION☐ MONITORING: A well bore schematic and map is required. No. of proposed wells: _____

5. Well Construction Information:

A. ☒ New well ☐ Modify ☐ Deepening ☐ Replace Previous Well # D-

B. Proposed Casing Diameter (in inches) 6" Proposed Maximum Depth (in feet) 200

C. Anticipated bottom hole temperature:

☒ 85°F or less
(Cold Water Well)☐ 85°F to 212°F
(Low Temp. Geo. Well)☐ 212°F or more
(Geothermal Well)

6. Construction Start Date: 06/16/2022

7. Drilling Company Name: NU ACRE DRILLING LLC

Driller's Lic. No. 701

NOTE: The actual well driller must be identified prior to drilling.

8. Applicant's Signature: [Signature] Date: 6/13/22

Title: CONSTRUCTION MANAGER

Address (if different than owner): 2317 N. WINDMILL WAY

City: KUNA State: ID Zip Code: 83634 Telephone: 951-673-6677

[Signature] Nu Acre Drilling LLC 208-941-0647

Drilling Permit No.: 905735
Receipt No.: W050517

Well ID: 469938
Printed: 06/17/2022

Metal Tag No.: D0097234
Approved Date: 6/16/2022

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
Well Drilling Permit**

Owner Type: Owner/Operator
Name: CAPITAL SHEET METAL
Address: 18155 GRAND AVE
LAKE ELSINORE, CA, 92530

Phone: 9516782000

Water Right No.:

Proposed Well Location: T: 04N, R: 04W, S: 23, QQQ: , QQ: SW, Q: NW
Latitude 43° 40.23' Longitude -116° 47.514'
County: CANYON

Street Address of Well Site: 19971 Monte Way
CALDWELL, ID

Lot: 4 Block: 3
Subdivision: Munn Ranch

Proposed Use of Well: Domestic-Single Residence

Well Construction Information:

Activity:	New Well
Proposed Surface Diameter:	6 Inches
Proposed Depth:	200 Feet
Anticipated Bottom Hole Temperature:	85F and less° F
Proposed Construction Start Date:	6/16/2022
Well Drilling Company:	NU ACRE DRILLING (No. 701)

If approved, this permit authorizes the construction or modification of a well subject to the following conditions:

Drilling Permit No.: 905735
Receipt No.: W050517

Well ID: 469938
Printed: 06/17/2022

Metal Tag No.: D0097234
Approved Date: 6/16/2022

- 1) This drilling permit is valid for two (2) months from the above approval date for the start of construction and is valid for one(1) year from the approval date for completion of the well unless an extension has been granted.
- 2) This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare, which may be required before construction of the well. All wells must be drilled a minimum distance of 100 feet from a drain field. Domestic and Public Water Supply wells must be drilled a minimum of 50 feet and 100 feet respectively from a septic tank.
- 3) The well shall be constructed by a driller currently licensed in the State of Idaho who must maintain a copy of the drilling permit and the well ID tag at the drilling site.
- 4) Approval of this drilling permit does not authorize trespass on the land of another party.
- 5) This permit does not constitute other local, county, state, or federal approvals which may be required for construction of a well.
- 6) This drilling permit does not represent a right to divert and use the water of the State of Idaho. If the well being drilled is associated with approved water right(s) use of the well must comply with conditions of said water right(s).
- 7) If a bottom hole temperature of 85°F (29.44 Degrees C) or greater is encountered, well construction shall cease and the well driller shall contact the Department immediately.
- 8) If the depth of this well exceeds 500 feet or the well is in an area known to have Low Temperature Geothermal water, bottom hole temperature must be measured and recorded on the Driller's Log, and reported on the Well Driller's Report.
- 9) Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (DigLine is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "DigLine" Number for your area is 1-800-342-1585.
- 10) The stainless steel I. D. tag must be securely and permanently attached to the well casing by the Driller upon completion of the well, and prior to removing the drill rig from the drill site and must remain permanently attached above ground level for the life of the well. The well tag shall be attached by welding at least 3 sides or using four (4) stainless steel, closed-end pop rivets.
- 11) Any well being replaced by a new well shall be properly abandoned by the well driller prior to removing the drilling equipment, unless otherwise authorized by the department.
- 12) The use of water from this well is for Domestic purposes only which includes irrigation of up to 1/2 acre of land with all combined uses not to exceed 13,000 gallons per day (42-111[A]), or for Domestic uses other than for homes, organization camps, public campgrounds or livestock where the diversion rate and volume does not exceed .04 cfs and 2500 gpd (42-111[B]).

Drilling Permit No.: 905735
Receipt No.: W050517

Well ID: 469938
Printed: 06/17/2022

Metal Tag No.: D0097234
Approved Date: 6/16/2022


This permit is Approved on 6/16/2022.

Aaron Skinner

208-334-2190

Print name of Authorized Dept. Representative

Phone Number



Sr. Water Resource Agent

Signature of Authorized Dept Representative

Title

June 17, 2022

CAPITAL SHEET METAL
18155 GRAND AVE
LAKE ELSINORE, CA 92530

PERMIT APPROVAL NOTICE

Re: PERMIT(s) : 905735

Dear Permit Holders(s):

The Department of Water Resources has issued the enclosed permit authorizing you to construct or modify a well. Please be sure to thoroughly review all the conditions of approval listed on your permit. The conditions may include additional requirements specific to your well. Failure to comply with the conditions of approval may result in an improperly constructed or unauthorized well.

This permit is a PRELIMINARY ORDER issued by the Department pursuant to Idaho Code § 67-5243. It can and will become a final order without further action by the Department unless a party petitions for reconsideration, files exceptions, or requests a hearing as described in the enclosed information sheet.

If you have any questions, please call me at (208) 605-4625.

Sincerely,

A handwritten signature in black ink, appearing to read 'Chad Jones', with a long horizontal flourish extending to the right.

Chad Jones
Technical Records Specialist 1

Enclosures(s)

CERTIFICATE OF SERVICE

I hereby certify that on June 17, 2022, I served a true and correct copy of Drilling Permit No. 905735 by U.S. Mail, postage prepaid, to the following:

CAPITAL SHEET METAL
18155 GRAND AVE
LAKE ELSINORE, CA 92530

- ☐ U.S. Mail, Certified, postage prepaid
- ☒ U.S. Mail, postage prepaid
- ☐ Overnight Mail
- ☐ Email



Chad Jones
Technical Records Specialist 1