

**STATE OF IDAHO**  
**DEPARTMENT OF WATER RESOURCES (IDWR)**

**MINIMUM ACCEPTABLE STANDARDS  
FOR OPEN CHANNEL AND CLOSED CONDUIT  
MEASURING DEVICES**

The source and means of diversion of water, whether surface or ground water, generally affects the selection of a measuring device. Surface water sources such as streams, springs and waste channels are normally diverted into open channels (ditches or canals), but closed conduits (pipes or culverts) are also used. Ground water is usually diverted into pipes (which may also discharge into open channels).

Measuring devices when required by IDWR are to be installed at or near the point of diversion from the public water source.

### **I. MEASUREMENTS IN OPEN CHANNELS**

The following discussion is applicable only to diversions from surface water sources. Measurement of a ground water diversion with an open channel measuring device must be pre-approved by the IDWR.

#### **A. Standard Open Channel Measuring Devices**

All open channel surface water diversions should be measured using one of the following standard open channel flow measuring devices commonly used in Idaho:

- **Weirs:** contracted or suppressed rectangular weirs, Cipolletti weir, 90 degree V-notch weir
- **Flumes:** Parshall flume, trapezoidal flume, ramped flume (ramped, broad-crested weir)
- **Submerged Orifices:** submerged rectangular orifice, constant head orifice
- **Acoustic:** acoustic Doppler flow meter (ADFM), acoustic Doppler current profiler

The installed flow rate accuracy of open channel measurement devices must be +/- 10.0% as compared to an acceptable open channel current meter or other standard portable measuring devices such as an acoustic Doppler flow meter or acoustic Doppler current profiler.

Construction, installation and operation of these devices should follow published guidelines, such as those published by the United States Bureau of Reclamation<sup>1</sup>

#### **B. Non-standard open channel devices: Rated Structures or Rated Sections**

Any weir, flume, or other measuring device that has not been constructed, installed, or maintained correctly and therefore does not measure flow in the standard manner consistent with standard rating tables or curves is considered to be a non-standard device. IDWR may authorize the use of non-standard devices and rated sections provided the device or section is rated or calibrated against a set of flow measurements using an acceptable open channel current meter or standard portable open channel measuring device. Examples of standard portable open channel measuring devices include the acoustic Doppler flow meter, the acoustic Doppler current profiler, or a portable flume. These devices are acceptable provided they are installed and operated according to all relevant manufacturer recommendations.

Further information and requirements are available from IDWR upon request.

---

<sup>1</sup> The Bureau of Reclamation measurement guidelines can be found at;  
[http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/BoR\\_WMM\\_%202001revision.pdf](http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/BoR_WMM_%202001revision.pdf)

## II. CLOSED CONDUIT MEASURING DEVICES

The following discussion is applicable to measurement of diversions from any water source that diverts via a full-flowing, closed conduit.

### A. Standard Closed Conduit Measuring Devices

A certified meter is required on new installations of measuring devices for closed conduit or pipe line diversions. A certified meter is a model of flow meter that has participated in independent third party testing and has been approved by IDWR for use. IDWR has published a list of meters that have participated in independent third party testing<sup>2</sup> and have been certified for use where the installation configuration and application meet manufacturer's requirements. Tests were conducted for both accuracy and repeatability on all submitted models, and a pass/fail rating awarded. A list of these meters may be found at:

[http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/Approved\\_flow\\_meter\\_list.pdf](http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/Approved_flow_meter_list.pdf).

Owners or operators who install a certified meter without the minimum manufacturer spacing requirements, or otherwise inconsistent with manufacturer's specifications, may need to provide an adequate testing section of straight pipe located somewhere on the diversion system either upstream or downstream of the installed flow meter. This testing section can be excavated pipeline as long as the section of pipe carries all water being measured through the installed flow meter. Water users choosing to expose pipe will be required to excavate the pipe at their expense at the request of the district hydrographer, watermaster and/or IDWR staff.

### B. Non-standard Closed Conduit Measuring Devices: Requests for Variance

In some cases, site conditions preclude use of a certified meter, and another meter or method of measurement will produce similarly accurate results. In cases where the user can show that a proposed alternative meter or method would be as accurate as, or otherwise is better suited to an application than any of the meters on the approved list, a user can propose using an alternative meter or method by submitting a Request for Variance Form, available from IDWR. If a request is submitted and granted, the water user bears the risk that the alternative meter or method will perform as expected.

The following alternate measurement methods may be considered:

- Development of a Power Consumption Coefficient (PCC), which is a ratio of power usage to water withdrawal. Acceptance of the PCC method may be provided *for qualifying irrigation diversions only*;
- Use of an hour meter (time clock) *for qualifying diversions only*;
- Use of an acceptable flow meter that was installed *prior to the date of the measurement order*;
- *For irrigation diversions only*, use of an acceptable non-certified flow meter where it can be shown that installation of a certified flow meter would be burdensome or ineffective.

If a meter is already installed, that meter may be used if the meter is field-tested by IDWR staff, the water district watermaster, or a district hydrographer using a portable standard flow meter and upon a determination that the meter is installed properly and accurate to within  $\pm 10\%$  of actual rate of flow and volume. If a non-certified meter is approved and installed but does not pass a field check, IDWR may require the water user to replace the meter with a certified meter at the water user's expense.

If an alternative method is approved and that method is later found to be insufficient, the variance will be withdrawn and a certified meter will be required to be installed. The suitability of any pumping station for an hour meter or the PCC method of measurement will be based on criteria found in this document and in the document entitled *IDWR ESPA Water Measurement and Reporting Guidelines*<sup>3</sup>.

<sup>2</sup> Testing was conducted at the Utah Water Research Laboratory (UWRL), a National Institute of Standards and Technology (NIST) traceable lab in Logan, Utah.

<sup>3</sup> This document can be found at:  
[http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/IDWRESPA\\_WaterMeasurement\\_ReportingGuidelines.pdf](http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/IDWRESPA_WaterMeasurement_ReportingGuidelines.pdf)