

RECEIVED

AUG 05 1994

WATER RESOURCES  
WESTERN REGION

MEMORANDUM

TO: Dave Tuthill  
Bob Sutter

FROM: TIM LUKE

DATE: August 4, 1994

RE: Payette River Diversion at Boise Cascade Emmett Plant

=====

Pursuant to Dave's request, I visited the Boise Cascade Emmett plant on August 3 and met with plant/regional supervisor Jim Spencer concerning their diversion. Mr. Spencer and I reviewed and toured the plant's diversion and conveyance system. A diagram of the system is attached.

Description of Diversion System and Uses:

The biggest use of the Payette River water within the plant is for the cogeneration power plant. Spencer estimates that about one-half million gallons of water per day are used for this purpose, and that total surface water use, including other uses, is perhaps near 1 million gallons per day. The cogeneration plant water requirements include mainly boiler and cooling tower make-up water. Two 60 hp pumps have been installed to divert water from the diversion system into the cogeneration plant. During my visit, only one of the pumps was in operation. This pump was operating at about 130 psi with about a 10 foot lift. These pumps are not metered.

Other uses of the surface water at the plant include dust control, fire protection, diversion to ponds for sprinkling logs, and cooling of plywood plant (sprinkle water on roof of plant). These other uses or diversions are very minor. As the sprinkling of logs uses recycled water, diversion to the ponds is only done perhaps several times per year. Watering of the logs is dependent on temperature and is usually done between March and November of each year.

Based on my review of the system, I did not find that the water is being metered or measured at any point between the headgate diversion, spill structures and the end uses. Current metering the Boise Cascade plant ditch diversion is currently the only way to measure the diversion to both Boise Cascade and the Smith Ditch. This combined diversion can be reduced by subtracting water that spills at two spillway structures. The first structure is located about 1000 ft. below the headgate structure. This spillway is a concrete dam about twenty feet wide. Spill over this structure can be estimated using a standard weir formula. The second spill site is located at the far western end of the plant, next to the heading of the Smith Ditch, and just above the City of Emmett water

treatment ponds. There is a small concrete structure here where wood stoplogs can be inserted. Spill over the stoplogs can again be estimated using a weir formula.

Comments of Jim Spencer, Boise Cascade

I could not determine really if Mr. Spencer was very concerned about the measurement of Boise Cascade's diversion. He did not appear to have a very favorable attitude toward any government agency, including Water District 65. He did not seem to be very enthusiastic about installing any standard meters or measuring devices. He doubted there was any economic incentive to install measuring devices, or help with, or participate in measuring the diversions when it is obvious that Boise Cascade is going to be charged for rental pool water whether they have accurate measurements or not. He felt that errors or differences in accuracy would not be significant when the cost of an acre-foot of storage is less than three dollars. On the other hand, I do not believe he was entirely comfortable with my suggestions about current metering and using weir formulas to estimate flows at the spill structures. I think he supported the concept of getting credit for the return flows. He did clearly state that measurement of the Smith Ditch is not Boise Cascade's responsibility, and that it probably should be measured and accounted for separately.

Spencer also stated that the fire protection element of the diversion system is critical to Boise Cascade. The water level in the ditch between the headgate and the first spill structure is intentionally maintained in order to guarantee sufficient water for fire protection. Also, because the main plant and cogeneration plant operates continuously for 24 hours per day, seven days per week, Boise Cascade is concerned about shutting their diversion down in order to install measuring devices or equipment etc. Spencer said shutting down the water diversion for any periods of time would be expensive and disruptive to operations.

Although Mr. Spencer seemed to be non-committed to measurement, he is interested in knowing what Boise Cascade should expect as far as what their rental pool use and charges will be this year and in future years. He was very concerned about the fact that Boise Cascade lacked ownership of any storage water. He is clearly not comfortable with the rental pool situation. I advised him to contact the Bureau of Reclamation concerning the acquisition of storage water. I further advised that we can probably provide Boise Cascade with such estimates based on Bob's runs and existing data. He is also interested in obtaining any information regarding this whole matter, including being advised of any future meetings between the Department, BOR and water users, and water district advisory committee meetings.

Recommendation for Future Measurements:

Since much of the Boise Cascade conveyance system consists of large buried culverts, there are very few places where water can be conveniently measured. I recommend at this time that the water district current meter and develop a rated section on the open

ditch channel between the main headgate and the first spill structure. Credit may applied to this diversion for return flows at the two spill structures. The Smith Ditch diversion can be included in the residual Boise Cascade diversion, or measured separately. If all return flow credit is applied, and the Smith Ditch is measured separately, the water district will have to make a total of four measurements for the Boise Cascade-Smith diversion.


Rating of Boise Cascade Ditch: I have current metered the Boise Cascade diversion ditch twice this year. Measuring the ditch is difficult because water backs up the ditch as a result of the first spill structure and buried culvert diversion. There are perhaps only two practical places where this ditch can be current metered. The first is in the concrete bays of the headgate diversion structure. The second site is about 300 feet below the headgates, on the downstream side of a large submerged culvert. I have made two current meter measurements at this latter site. The first site provides a better control for a rated section, but may be less reliable at lower flows. I believe that we can develop a reasonable rating for either site.

Spill Structure Concerns: Flows at the two spill structures can be estimated using standard weir formulas. The water district and users need to be aware that these structures are not standard weir structures. The stoplogs in the second spill structure are sometimes removed. When this occurs, the return flow can only be measured by current metering the return flow channel. A standard weir could be placed further down the return flow channel and below the stoplog control structure.

Smith Ditch: This ditch is poorly maintained and has a very silty bottom. In addition, the ditch is rather flat and wide for the given range of flows encountered. There appears to be no suitable location to install a measuring device or develop a rated section anywhere near the headgate. The only accessible part of the ditch that has any measurement potential is at the main entrance to the City treatment ponds about 1500 feet below the headgate.

#### Summary of 1994 measurements:

- 1) June 8, 1994
  - Current metered 15.46 cfs at diversion ditch 300 ft. below headgate. No spill water occurring at first spill structure. Current metered 10.58 cfs return flow at second spill site. Wood stoplogs here were either pulled or submerged and could not provide reasonable estimate using weir formula. Combined Boise Cascade-Smith Ditch use is the difference between the two measurements, or 4.88 cfs.
- 2) July 26, 1994
  - Current metered 32.26 cfs at diversion ditch 300 ft. below headgate. Measured about 19 cfs return flow over first spill structure using weir formula. Did not measure return flow at second spill structure. Combined Boise Cascade-Smith diversion was about 13 cfs including return flow at second spill site.



Log River

Fiber Optic Pumps

Culvert

Spill Structure

Boise Cascade Ditch

Buried Culvert to Plant  
 -- to Co-Gen Plant & Pond Dimensions

Log River

Ponds

Pumps from Pond to Log Spunking

Cogen Plant

Z, GHP Pumps

Concrete Well House  
 Headgate to Cogen Plant

Buried Culvert

Buried Culvert

Open Ditch Channel

Stoplog Spill Structure

Head Gate Smith Ditch


Smith Ditch

City Ponds

to River

Headgates

Culvert



Head  
Smith Ditch

HEAD GATE  
BOISE-CASCADE PLANT



# State of Idaho

## DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000  
 Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS  
GOVERNOR

R. KEITH HIGGINSON  
DIRECTOR

### MEMORANDUM

TO: Helen Bivens  
 FROM: Bob Sutter  
 SUBJECT: Revised 1994 Payette River Storage Fill

DATE: August 5, 1994

Attached is the new storage fill for 1994 using the revised procedure for computing accounts within each reservoir as agreed upon at our July 29, 1994 meeting. Each fill category is filled proportional to the owner's space in that category instead of proportional to the owner's space in the entire reservoir. For 1994, the only changes are in the Cascade last-to-fill category. The changes in storage accrual are as follows:

Farmers Coop	=	+3255.1 AF
Noble	=	+785.3 AF
Lower Payette	=	+2447.5 AF
USBR uncontracted	=	-6487.9 AF

These values include estimated losses to evaporation, but do not include operational losses.

Also reflected in Table 4 of this attachment is the transfer of Upper Lakes storage from the Lower Payette Canal Co. to the other spaceholders in the Upper Lakes. This transfer was 6000.6 acre-feet. I have apportioned the Letha Irrigation District storage to their canals based on their estimated storage use.

Please check over these numbers and let me know if you feel they are correct. As soon as they are final, I will revise the storage remaining values in the daily accounting.

BS:cjk  
 Attachment  
 cc: Rick Wells  
 Dave Tuthill



RECEIVED

JUL 08 1994

WATER RESOURCES  
WESTERN REGION

**ELAM & BURKE**  
*A Professional Association*  
ATTORNEYS AND COUNSELORS AT LAW  
*Established in 1928*

KEY FINANCIAL CENTER  
702 WEST IDAHO  
POST OFFICE BOX 1539  
BOISE, IDAHO 83701

TELEPHONE  
208-343-5454

FACSIMILE  
208-384-5844

SCOTT L. CAMPBELL

July 7, 1994

Mr. John W. Keyes, III  
Regional Director  
Pacific Northwest Region  
U.S. Bureau of Reclamation  
1150 North Curtis Road  
Boise, Idaho 83704

Dear John:

I am writing on behalf of my client, the Payette River Water Users Association, Inc., a non-profit corporation which consists of various canal companies, irrigation districts, and private water users, utilizing the surface water of the Payette River.

I am writing concerning the proposed water bank water lease agreement for 1994, dated May 19, 1994 (copy enclosed).

The purpose of this correspondence is to advise you of existing legal restrictions upon the use of water for salmon flow augmentation and to request confirmation of your acceptance and agreement with certain procedures relating to use of water from the Payette River for salmon flow augmentation.

First, you should be aware that Section 4.2 of the Water District No. 65 Rental Pool Procedures places management of the rental pool in the District No. 65 Water Master. This authority extends to distribution of rental water. Consequently, despite the language of the draft water bank water lease agreement for 1994, distribution of the water will be subject to the control of Ms. Helen Bivens, Water Master for Water District No. 65.

Second, you should be aware that Section 5.4 of the Water District No. 65 Rental Pool Procedures specifies that leases which have been accepted by the Water Master are subject to the review and approval of the Advisory Board of Water District No. 65. Accordingly, acceptance of any lease by the Water Master is contingent and conditional until the Advisory Board of District No. 65 has taken action on the lease.



Mr. John W. Keyes, Jr.  
July 7, 1994  
Page Two

---


Because of the concerns which my client has regarding the accounting procedures and water releases which occurred from Bureau of Reclamation facilities in 1993, we request written confirmation of the Bureau's consent to regulation of salmon flow augmentation water by the District No. 65 Water Master, pursuant to a water bank water lease agreement and the Water District No. 65 Rental Pool Procedures. Regulation of the water by the Water District No. 65 Water Master will include accounting for the quantities of water released and regulation of the flows of the Payette River based upon documented requests for release of water. This accounting will be performed in conjunction with the Western Region Office of the Idaho Department of Water Resources.

These procedures are requested of the Bureau of Reclamation in order to provide the necessary assurance to my client that the water releases will be conducted in a controlled, supervised manner. My clients have substantial concerns that if the Bureau of Reclamation does not agree to follow these procedures, other more drastic steps will have to be taken.

Thank you for your anticipated response.

Very truly yours,

ELAM & BURKE  
*A Professional Association*

  
Scott L. Campbell

SLC:ma

cc: Ms. Helen Bivens, Water Master, Water District No. 65  
Payette River Water Users Association, Inc.  
David R. Tuthill, Jr., P.E., Western Region Manager  
Idaho Department of Water Resources

MEMORANDUM

TO: DEBBIE ALLEN

FROM: TIM LUKE *TL*

DATE: June 7, 1994

RE: INVOICE TO WATER DISTRICT 65 FOR STAFF GAGES

=====

I would like the Department to submit an invoice to State Water District No. 65, Payette River Basin, for partial reimbursement of three water level gages. We provided the District with two Stevens Type A steel staff gages, 0-3.33 ft., and one Stevens Type C steel staff gage, 0-3.33 ft. Please remit a bill for the amount of \$75.00 to:

Water District 65  
C/O Helen Bivens  
102 N. Main St.  
Payette, ID 83661

IDWR cost for Type A and Type C gages is \$37.00 and \$27.00 each respectively. The reduced cost to the District 65 is a cost share (about 1/4 cost by IDWR) to assist district with water distribution and measurement. Water Allocations purchased gages this year from Water and Waste Water Equipment Co. in Boise. PCA code no. 56008 was used in purchasing gages and should be used in receiving any funds in resale of gages to districts.

cc: Helen Bivens, Water District 65 Watermaster

RECEIVED

JUL 06 1994

WATER RESOURCES  
WESTERN REGION

MEMORANDUM

TO: HELEN BIVENS

FROM: TIM LUKE

DATE: July 5, 1994

RE: WEIR TABLE AND REVISED RATING TABLE FOR 7 MILE SLOUGH

=====

Upon meeting with Don and Rick York on July 1, I learned that there were some incorrect discharge rates for several gage heights on the rating table for the Seven Mile Slough. Enclosed is a corrected version of the rating table.

Also enclosed is a discharge table for a 5.5 ft. rectangular contracted weir which can be used for the weir check structure in the wasteway channel above the Tunnel 7 barrels. Don and Rick had asked whether this structure could be used as a weir in lieu of establishing a rated section on the short channel near the barrels. Don stated that the new stilling well he installed near the barrels was being effected by flows in the Seven Mile Slough. We concluded that the new stilling well could not be used to help generate an accurate or reliable rating table for the barrels diversion, and that using the check structure above the barrels as a weir would be a better alternative. When using this structure, the barrels diversion will be the difference between the flows at the weir check structures above and immediately below the barrels. Don should also subtract an estimated discharge from the instream pump located between the two weir check structures.

I also suggested to Don and Rick that a sharp crested weir blade be placed along the crest and edges of the open notch of the concrete check structure. A few current meter measurements at different flows should be made just below or above this structure to verify the accuracy of the weir structure, and make any calibrations if necessary.

Call me if you have questions concerning this material.

cc: Don York  
Bob Sutter  
Dave Tuthill

DISCHARGE OF STANDARD CONTRACTED RECTANGULAR  
Wasteway check/weir structure above Tunnel 7 Barrels  
Where weir crest length (L) = 5.5 ft.

Head (H) in Feet	Discharge (Q) CFS	Head (H) in Feet	Discharge (Q) CFS
0.04	0.15	0.55	7.47
0.05	0.20	0.56	7.68
0.06	0.27	0.57	7.88
0.07	0.34	0.58	8.09
0.08	0.41	0.59	8.30
0.09	0.49	0.60	8.51
0.10	0.58	0.61	8.73
0.11	0.67	0.62	8.94
0.12	0.76	0.63	9.16
0.13	0.86	0.64	9.38
0.14	0.96	0.65	9.60
0.15	1.06	0.66	9.82
0.16	1.17	0.67	10.04
0.17	1.28	0.68	10.27
0.18	1.40	0.69	10.50
0.19	1.52	0.70	10.73
0.20	1.64	0.71	10.96
0.21	1.76	0.72	11.19
0.22	1.89	0.73	11.42
0.23	2.02	0.74	11.66
0.24	2.15	0.75	11.90
0.25	2.29	0.76	12.13
0.26	2.43	0.77	12.37
0.27	2.57	0.78	12.62
0.28	2.71	0.79	12.86
0.29	2.86	0.80	13.11
0.30	3.01	0.81	13.35
0.31	3.16	0.82	13.60
0.32	3.32	0.83	13.85
0.33	3.47	0.84	14.10
0.34	3.63	0.85	14.35
0.35	3.79	0.86	14.61
0.36	3.96	0.87	14.86
0.37	4.12	0.88	15.12
0.38	4.29	0.89	15.38
0.39	4.46	0.90	15.64
0.40	4.63	0.91	15.90
0.41	4.81	0.92	16.16
0.42	4.99	0.93	16.43
0.43	5.16	0.94	16.69
0.44	5.35	0.95	16.96
0.45	5.53	0.96	17.23
0.46	5.71	0.97	17.50
0.47	5.90	0.98	17.77
0.48	6.09	0.99	18.04
0.49	6.28	1.00	18.31
0.50	6.48	1.01	18.59
0.51	6.67	1.02	18.87
0.52	6.87	1.03	19.15
0.53	7.07	1.04	19.42
0.54	7.27	1.05	19.71

**DISCHARGE OF STANDARD CONTRACTED RECTANGULAR**  
Wasteway check/weir structure above Tunnel 7 Barrels  
Where weir crest length (L) = 5.5 ft.

Head (H) in Feet	Discharge (Q) CFS	Head (H) in Feet	Discharge (Q) CFS
1.06	19.99	1.57	36.03
1.07	20.27	1.58	36.37
1.08	20.56	1.59	36.72
1.09	20.84	1.60	37.07
1.10	21.13	1.61	37.41
1.11	21.42	1.62	37.76
1.12	21.71	1.63	38.11
1.13	22.00	1.64	38.47
1.14	22.29	1.65	38.82
1.15	22.59	1.66	39.17
1.16	22.88	1.67	39.53
1.17	23.18	1.68	39.88
1.18	23.48	1.69	40.24
1.19	23.78	1.70	40.60
1.20	24.08	1.71	40.95
1.21	24.38	1.72	41.31
1.22	24.68	1.73	41.68
1.23	24.98	1.74	42.04
1.24	25.29	1.75	42.40
1.25	25.60	1.76	42.76
1.26	25.90	1.77	43.13
1.27	26.21	1.78	43.49
1.28	26.52	1.79	43.86
1.29	26.83	1.80	44.23
1.30	27.15	1.81	44.60
1.31	27.46	1.82	44.97
1.32	27.78	1.83	45.34
1.33	28.09	1.84	45.71
1.34	28.41	1.85	46.09
1.35	28.73	1.86	46.46
1.36	29.05	1.87	46.83
1.37	29.37	1.88	47.21
1.38	29.69	1.89	47.59
1.39	30.01	1.90	47.97
1.40	30.34	1.91	48.35
1.41	30.66	1.92	48.73
1.42	30.99	1.93	49.11
1.43	31.32	1.94	49.49
1.44	31.65	1.95	49.87
1.45	31.98	1.96	50.26
1.46	32.31	1.97	50.64
1.47	32.64	1.98	51.03
1.48	32.98	1.99	51.41
1.49	33.31	2.00	51.80
1.50	33.65	2.01	52.19
1.51	33.98	2.02	52.58
1.52	34.32	2.03	52.97
1.53	34.66	2.04	53.36
1.54	35.00	2.05	53.76
1.55	35.34	2.06	54.15
1.56	35.69	2.07	54.55

05-Jul-94

SEVEN MILE SLOUGH

LINEAR RELATIONSHIP BETWEEN DATA POINTS

COMPILED BY IDWR, JUNE 1994

Q = (GHT - 0.5315)/0.003863 for gage heights 1.35 thru 1.60 ft.

Q = (GHT - 0.758)/0.003045 for gage heights 1.61 thru 2.90 ft.

```

*****
GHT      0.000      0.010      0.020      0.030      0.040      0.050      0.060      0.070      0.080      0.090
*****
1.300
1.400 224.825 227.414 230.003 232.591 235.180 237.769 240.357 242.946 245.535 248.123
1.500 250.712 253.301 255.889 258.478 261.067 263.655 266.244 268.833 271.421 274.010
1.600 276.598 279.803 283.087 286.371 289.655 292.939 296.223 299.507 302.791 306.076
1.700 309.360 312.644 315.928 319.212 322.496 325.780 329.064 332.348 335.632 338.916
1.800 342.200 345.484 348.768 352.053 355.337 358.621 361.905 365.189 368.473 371.757
1.900 375.041 378.325 381.609 384.893 388.177 391.461 394.745 398.030 401.314 404.598
2.000 407.882 411.166 414.450 417.734 421.018 424.302 427.586 430.870 434.154 437.438

```