



State of Idaho

DEPARTMENT OF WATER RESOURCES

1341 Fillmore Street, Suite 200, Twin Falls ID 83301-3380

Phone: (208) 736-3033 FAX: (208) 736-3037

SOUTHERN REGION

DIRK KEMPTHORNE
Governor

KARL J. DREHER
Director

July 18, 2003

Cindy Blakely
933 S 2030 W
Murtaugh, ID 83344

RE: Harold Frazier Diversion On Rock Creek

Dear Cindy;

Attached is a copy of the measuring-device certification done by Corbin Knowles of this office yesterday. Before the flow meter was re-calibrated, it was over 16% high; readings before then should be multiplied by 0.86. Future readings should be multiplied by 1.01 to determine the true diversion rate. If you have questions, contact Corbin.

Regards,

James E. Stanton
Sr. Water Resource Agent