



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Boise, ID 83706 - P.O. Box 83720, Boise, ID 83720-0098
Phone: (208) 327-7900 Fax: (208) 327-7866 Web Site: www.idwr.state.id.us

DIRK KEMPTHORNE
Governor

KARL J. DREHER
Director

March 23, 2004

Frank Erwin
Watermaster, Water District 36A
2628 S 975 E
Hagerman, ID 83332

Re: Proposed Buckeye Ditch 10' rectangular weir

Dear Frank,

I have reviewed the plans you provided IDWR for the proposed weir at the Buckeye Ditch. These plans show sufficient detail, except as noted below, for proper construction and placement of the new weir. One additional note that should be included is that the weir plate should be level, plumb, and the weir floor should have no slope, or as near as practicle for rough formed concrete construction.

The proposed size of weir also should be sufficient for the range of flows on record for the Buckeye Ditch.

This letter should be considered as certification of approval that the proposed measuring device meets or exceeds IDWR standards. If you have further questions, don't hesitate to call.

Sincerely

A handwritten signature in cursive script that reads "Steve Burrell".

Steve Burrell, P.E.
Water Distribution Section

c: Water District file
Buckeye ditch measurement file