



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

JULY 10, 2008

C. L. "BUTCH" OTTER
Governor

DAVID R. TUTHILL, JR.
Director

JAMES R. BENNETTS
P.O. BOX 36
CHALLIS, ID 83226-0036

RE: WATER MEASURING DEVICES – STANHARRAH, A NEVADA CORPORATION

Dear Mr. Bennetts:

I met with John Varadi in Stanley recently as a follow-up to my visit last summer to discuss measurement of the groundwater diversions at the Mountain Village. Mr. Varadi has shown me each of the wells in Stanley that divert water rights owned by the Stan Harrah Corporation and described the use of each well. Based on this information, I have been able to update the IDWR records to more accurately reflect which water rights are diverted from each well. As a result, it is now clear that only well numbers 12, 17, and 19 must be measured to comply with the February 20, 2007 IDWR order requiring measurement and control in Water District No. 170. Furthermore, as these three wells are interconnected they can be adequately measured with one measuring device placed below the confluence of the three wells.

I have attached a map indicating the locations of the Stan Harrah wells and the water rights diverted from each well. Please contact me if you notice any inconsistencies between your understanding of the water rights and what is presented in the table.

Assuming the water rights are correct, please contact me with plans for installing a flow meter on each of the three wells, or for installing a flow meter on the downstream side of well number 12 at a point on the pipe that will measure the combined flow from all three wells.

IDWR's current standards for closed conduit meters are attached for your reference. Those standards require magnetic flow meters. While the magnetic type flow meters tend to be more expensive than the propeller type, our experience indicates there is a long-term savings due to the longevity of the meter compared with propeller type meters.

The order requiring measurement and control requires diversions to be brought into compliance by June of 2008. As this date has passed, it is important that these wells be brought into compliance as expeditiously as possible. Therefore, I ask that plans for measuring these wells be submitted to IDWR no later than Friday, November 5, 2008 and that installation of the measuring devices be completed as soon thereafter as possible.


Mr. James Bennetts

July 10, 2008

Page 2 of 2

I appreciate your cooperation on this matter. Particularly, I want to thank Mr. Varadi for following up on this issue and for taking the time to meet with me. If I can be of further help, please feel free to contact me at (208-287-4956). Otherwise, I look forward to hearing back from you with plans for measurement and on whether the water rights appear correct.

Sincerely,

A handwritten signature in black ink, appearing to read 'Nick Miller', written over a faint, illegible typed name.

Nick Miller, P.E.

Water Distribution Section

Enclosures:

Map of Stan Harrah's wells in Stanley, ID – 1 page @ 8.5"x11"

Minimum Acceptable Standards for Open Channel and Closed Conduit Measuring Devices – 4 pages

cc.

STAN HARRAH CORP - PO BOX 12968 RENO, NV 89510

S:\Correspondence\2008\2008 HGMD Correspondence\Basin 71\071008Harrahs.doc

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES (IDWR)**

**MINIMUM ACCEPTABLE STANDARDS FOR
OPEN CHANNEL AND CLOSED CONDUIT
MEASURING DEVICES**

The source and means of diversion of water, whether surface or ground water, generally affects the selection of a measuring device. Surface water sources such as streams, springs and waste channels are normally diverted into open channels (ditches or canals), but closed conduits (pipes or culverts) are also used. Ground water is usually diverted into pipes (which may also discharge into open channels).

Measuring devices when required by IDWR are to be installed at or near the point of diversion from the public water source.

Open Channel

I. SURFACE WATER DIVERSIONS

The following discussion is applicable only to diversions from surface water sources. Measurement of a ground water diversion with an open channel measuring device must be pre-approved by the IDWR.

A. Standard Open Channel Measuring Devices

All open channel surface water diversions should be measured using one of the following standard open channel flow measuring devices commonly used in Idaho:

- contracted rectangular weir
- suppressed rectangular weir
- Cipolletti weir
- 90 degree V-notch weir
- Parshall flume
- trapezoidal flume
- submerged rectangular orifice
- constant head orifice
- ramped broad crested weir (or ramped flume)
- acoustic Doppler flow meter (ADFM)

Construction and installation of these devices should follow published guidelines. References are available upon request.

B. Non-standard open channel devices: Rated Structures or Rated Sections

IDWR may authorize the use of non-standard devices and rated sections provided the device or section is rated or calibrated against a set of flow measurements using an acceptable open channel current meter or a standard portable measuring device. Further restrictions and requirements are available from IDWR upon request.

II. CLOSED CONDUIT MEASURING DEVICES

Closed conduit or pipe line diversions require installation of a flowmeter.

There are many flowmeters on the market, with costs ranging from several hundred dollars to several thousand dollars. In general, the higher priced meters are more accurate and require less maintenance. Most meters on the market have an acceptable accuracy rating for IDWR's guidelines. However, some types and designs are much more prone to maintenance problems. Moving parts tend to wear when sand or silt is present, and moss often plugs small orifices and slows moving parts. No single flowmeter is best for every situation. We recommend that you visit with qualified dealers and discuss your needs with them.

A. Flow Meter Specifications

Listed below are the flow meter requirements and specifications for full-flowing closed conduits or pipes. These specifications apply to all irrigation and non-irrigation water uses except domestic systems as defined in Section 42-111, Idaho Code. Water users may apply to IDWR for a variance to these specifications in accordance with Criteria for Request for Variance of measuring Device Requirements of Section II C. of this document

Meters shall be magnetic flow meters meeting the following minimum specifications:

- 1) Flow range of 0.1 to 33 feet per second (fps).
- 2) Listed manufacturer accuracy of $\pm 0.5\%$ of flow rate from 1.6 to 33 feet per second (fps), and $\pm 2\%$ of flow rate from 0.1 to 1.5 feet per second (fps).
- 3) The register or display unit shall:
 - a) Have a waterproof and tamperproof seal.
 - b) Have an LCD backlit display showing instantaneous flow rate and totalized volume.
 - c) Have a minimum of six (6) digits for flow rate.
 - d) Have a minimum of eight (8) digits for totalized volume display or a sufficient number of digits so that "rolling over" will not occur within two years operation, based on the maximum rate of flow and annual volume elements of the authorizing water rights. For totalizing data, IDWR recommends using the attached guidelines (see Table 1) for proper meter (totalizing units) selection for the intended use.
 - e) Have password or similar protection of all settings and data to protect against unauthorized change or accidental loss of data.
 - f) Contain a back up battery (according to manufacturers specifications) to prevent loss of data in the case of primary power failure.
 - g) The display unit must contain user programmable features that allow the selection of flow units. Available flow units must include, but are not limited to, gallons per minute (gpm) or cubic feet per second (cfs). The meter flow rate display must also allow decimal display formatting of up to three (3) places when using cubic feet per second units.
 - h) The volume totalizer display must contain user programmable features that allow the selection of volumetric units that must include but are not limited to, total gallons or acre feet. The meter must also allow decimal display formatting of up to four (4) places, and the application of unit multipliers ranging from .0001 to 10,000.

4) Signal Output when Data Logger is Required

Data loggers are required only for magnetic flow meters installed as per conditions of approval for water right transfers in the Eastern Snake Plain Aquifer, or as may be required by specific water right conditions of approval in other locations.

Scaled pulse frequency output (or pulse counting) is required for continuous recording of totalized volume data on data loggers. Output signals must be compatible with data logger inputs. Analog output signal for flow rate (usually 4-20mA) is also optional (most magnetic flow meters provide both analog and pulse frequency as standard output signals).

B. Meter Installation and Diversion System Requirements

Meters required under Section II A. above shall meet the following installation requirements:

- 1) The minimum and maximum system operating flows and pressures must be fully within the range of measurable flows and pressures identified in the meter specifications.
- 2) Pipes must be full flowing.
- 3) The installed flow rate accuracy of the installed magnetic flow meter must be $\pm 5.0\%$ as compared to a second, standard flow meter. The installed flow rate accuracy for mechanical flow meters is $\pm 10\%$ of rate of as compared to a second, standard flow meter.
- 4) Meters must be installed according to manufacturer's specifications. Most manufacturers' recommend that meters be installed a certain distance from turbulence-causing bends and fittings such as discharge heads, single elbows, and valves. Industry standards for such distances are listed below, but larger distances may be required if the turbulence is severe.
 - a. Magnetic flow meters require three (3) pipe diameters upstream of the meter and two (2) downstream.
 - b. Mechanical flow meters require ten (10) pipe diameters upstream of the meter and five (5) pipe diameters downstream.
- 5) Meter Certification: IDWR will certify the installed flow meter for accuracy using a second, standard flow meter. A location for measuring flow with a second standard meter must be provided as close to the installed meter as possible. A section of straight pipe with a minimum of 24 inches in length (for pipe diameters 16 inches and smaller) of unobstructed exposed pipe shall be provided for calibration purposes. The calibration section must be free of elbows, valves and other fittings, and must contain the same flows that are passing through the meter. The 24-inch certification section may be incorporated into the manufacturer's pipe requirements above or below the flow meter.

C. Requests for Variance of Closed Conduit Measuring Device Requirements

Owners of closed conduit diversions may request a variance of the standard magnetic flow meter requirements of section II A. above for the following reasons:

- a) An operable flow meter is already installed
- b) Installation and maintenance of the standard meter would be burdensome

If a meter is already installed, that meter may be used if the meter is field-tested by IDWR staff and/or the water district watermaster using a portable certified standard flow meter and upon a determination that the meter is installed properly and accurate to within $\pm 10\%$ of actual rate of flow and volume. ***IDWR or the water district watermaster should apply a calibration factor to flow meters whenever the calibration measurement is greater than $\pm 1.0\%$.***

If a user demonstrates that installation and maintenance of the standard meter would be burdensome, then IDWR may consider alternate measurement options including:

- a) Development of Power Consumption Coefficient to estimate water use volumes (generally acceptable for simple ground water irrigation diversion systems only)
- b) Installation of one or more time clocks or hour meters (requires periodic flow measurements and recording of hours of water use from meter or clock)
- c) Installation of an alternative flow meter as shown in Table 2 below.

Users considering making a variance request may contact IDWR or the local water master for further information.

Table 1; Use for proper meter selection based on water right volume.

Volume Acre Feet (AF)	Multiplier X gallons (gal)	Multiplier X Acre Feet (AF)
0-150	1, 10, 100	.0001, .001
150-1000	10, 100, 1000	.001, .01
>1000	100, 1000	.001, .01

Table 2; Types of Measuring Devices for Closed Conduits

Types	Pipe Sizes	Maintenance Required	Relative Purchase Price
Differential Head <ul style="list-style-type: none"> • Orifice • Venturi • Annubar 	small to large	Low to high. Sand wears on sharp edges, and particles can plug small orifices and tubes.	low to medium
Force Velocity <ul style="list-style-type: none"> • Turbine • Propeller • Impeller 	small to large	Typically moderate to high. Often problematic when exposed to sand or moss. Some cannot measure low velocities	low to medium
Ultrasonic or Acoustic Doppler	small to large	Low. Typically non-invasive with no moving parts to wear	high
Vortex	small to medium (about 12 to 14 inch maximum pipe diameter)	Low. Few or no moving parts to wear.	high