

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

WATER DISTRICT NO. 37 & 37 M

P.O. Box T
Shoshone, Idaho 83352
(208) 886-2451

July 16, 2001

Robert Dreyer
P O Box 4917
Ketchum, Idaho 83340

COPY



RECEIVED LEE R. PETERSON
JUL 17 2001
Department of Water Resources
Southern Region
Watermaster

Dear Mr. Dreyer,
Our Deputy has advised me that the meter on your pump is not working, and as a result he cannot make accurate measurement of your water.

Idaho Code 42-701 states in part:

"The appropriators or users of any public waters of the state of Idaho shall maintain to the satisfaction of the director of the department of water resources suitable headgates and controlling works at the point where their water is diverted. Each device shall be of such construction that it can be locked and kept closed by the watermaster or other officer in charge, and shall also be of such construction as to regulate the flow of water at the diversion point."

Failure to do so may result in the director of water resources instructing the watermaster to shut off and refuse to deliver at the point of diversion, the water owned by such appropriator or user until the user does construct and maintain such headgates, controlling works or measuring devices or remedy the defects which exist.

This meter needs to be repaired or replaced on or before August 1, 2001 at which time the pump will be locked up until the necessary repairs are made.

If we can be of any assistance please feel free to call.

Sincerely,

A handwritten signature in cursive script, reading "Lee R. Peterson".

Lee R. Peterson
Watermaster

CC: IDWR