

From: DWR03::TLUKE 17-DEC-1997 11:13:49.61
To: DWR60::AMERRITT
CC:
Subj: Re: Discussion w/Frank Erwin: Musser Pump/Schrank Complaint

I spoke with Frank Erwin today. I had asked Frank to measure the Curren Ditch diversion. They are diverting about 32.5 cfs, which is easily 10 cfs more than they are entitled to in the winter. I may follow up with some direction about regulating that diversion. I'll talk to Norm or Glenn first.

I also asked Frank about the Musser pump that was part of the Schrank complaint which you addressed. Frank said that Musser changed his pump on this diversion either this spring (1997) or in 1996. This change would be subsequent to my field measurement and PCC deriovation of 1995. My discharge measurement and PCC from 1995 is most likely not valid any longer for estimating Mussers annual volume. We think that the pump may have been changed in '96 because our volume estimate for '96 is significantly higher than '95. However, Musser did not report a pump or system change on his '96 report for this pump.

This is all FYI.

Jim

*Please place this copy
in file 36-A with
the other Schrank
complaint letters.*

[Signature]
