

**Idaho Dept of Water Resources
ESPA Spring Diversion Inventory**

District 36A Date 7/13/2004
 Basin 36 Ditch or users association Hagerman Water Users
 Diversion Name Hagerman Water Users POD Number _____
 Spring Name N. Spring, S. Spring Tunnel, other ^{small} springs Tributary to Billingsley Creek
 GPS site ID (also Sherman Springs if irrigator is off) Inventory Examiner J. Berkeley
 Owner _____ Operator _____

Measuring Device Data	
Type of Device or Method	<u>4.12 foot suppressed rect weir</u> Standard <input type="radio"/> Non-standard <input checked="" type="radio"/>
If non-standard describe: <u>Submerged, no ventilation for nappe</u>	
Discharge and Measurement Method	
How Measurement was taken: (Staff gauge, current meter, polysonic meter)	<u>staff gage</u>
Staff gauge Head Reading 2.69 <u>0.70</u>	Current Meter/or poly-sonic measurement: 8.34 <u>8.34 cfs</u>
Time of Day <u>5:40 PM</u> 11:00 AM <u>7/14</u>	
Table used for Q <u>standard suppressed weir</u> not adequate device eqn	Meter Measurement Confidence 2% <input checked="" type="radio"/> 5% <input type="radio"/> 10% <input type="radio"/> +10% <input type="radio"/> <u>NA</u>
Total Flow = <u>8.04 cfs</u> cannot determine from MD	Does device meet IDWR standards? <input checked="" type="radio"/> YES <input checked="" type="radio"/> NO
Discharge notes attached? <input checked="" type="radio"/> YES <input checked="" type="radio"/> NO	Measurement Taken by: <u>J. Berkeley</u>
Calculations Attached? <input checked="" type="radio"/> YES <input checked="" type="radio"/> NO	Is follow-up Needed? <input checked="" type="radio"/> YES <input checked="" type="radio"/> NO

Concerns about measuring device: not adequate, submerged, no air pocket
4.12 feet in length (steel plate)

Aquarius Aquaculture

410087 Hidden Springs Hatchery

Huff

5:50pm

staff gage measurement @ heading of raceways

RW1 L=4.30 h=0.21

RW2 L=4.26 h=0.22

RW3 checked off

RW4 checked off

other pond area dry

suppressed rect weir - non-standard; 1.5" ~~thick~~ thick boards

source is same spring complex as Hagerman water users - collection ditch is lower than Hagerman water users', so he captures some water that they can't.

In winter he also gets the water they use during irrig season.

Fish Dev

R RW L=3.03 h=0.50 → 8" PVC standpipe for drain right in front of ~~weir~~ middle of weir - needs to be removed

Current meter measurement

Site: Hegerman Water Users
 Date: 7/14/2004
 WMS ID: 410044
 Source: Springs (north spring, south spring tunnel, other small springs, Sherman Springs when Sherman Springs irrigation pipeline is off)

Staff gage readings: 0.70 feet @ 10:30 AM
 0.70 feet @ 11:35 AM

Meter type: Suppressed rectangular weir
 Weir Length: 4.12 feet
 Rating curve: Standard suppressed rectangular weir equation
 Meter discharge: 8.04 ft³/s

Measured in north ditch and south ditch approximately 200 feet upstream of weir

South Ditch	Distance	Depth	Obs Depth	Velocity	Width	Area	Discharge
REW	feet	feet	feet	ft/sec	feet	ft ²	ft ³ /s
	1.1	0.00			0.2		
	1.5	0.32	0.6	0.94	0.45	0.144	0.13536
	2.0	0.75	0.6	1.12	0.5	0.375	0.42
	2.5	0.96	0.6	1.29	0.5	0.48	0.6192
	3.0	1.13	0.6	1.40	0.5	0.565	0.791
	3.5	1.25	0.6	1.36	0.5	0.625	0.85
	4.0	1.29	0.6	1.19	0.5	0.645	0.76755
	4.5	1.32	0.6	1.17	0.5	0.66	0.7722
	5.0	1.30	0.6	1.09	0.5	0.65	0.7085
	5.5	1.29	0.6	0.90	0.5	0.645	0.5805
	6.0	1.34	0.6	0.72	0.5	0.67	0.4824
	6.5	1.38	0.6	0.59	0.5	0.69	0.4071
	7.0	1.37	0.6	0.42	0.5	0.685	0.2877
	7.5	1.23	0.6	0.23	0.5	0.615	0.14145
	8.0	1.11	0.6	0	0.7	0.777	0
	8.9	0.00			0.45		
South Ditch Total					7.8	8.226	6.96

North Ditch	Distance	Depth	Obs Depth	Velocity	Width	Area	Discharge
LEW	feet	feet	feet	ft/sec	feet	ft ²	ft ³ /s
	1.4	0			0.3		
	2.0	0.36	0.6	0.68	0.55	0.198	0.13464
	2.5	0.44	0.6	0.90	0.5	0.22	0.198
	3.0	0.60	0.6	1.05	0.3	0.3	0.315
	3.5	0.69	0.6	1.12	0.375	0.25875	0.2898
	3.75	0.73	0.6	0.89	0.25	0.1825	0.162425
	4.0	0.71	0.6	0.59	0.375	0.26625	0.157088
	4.5	0.53	0.6	0.46	0.375	0.19875	0.091425
	4.75	0.43	0.6	0.23	0.25	0.1075	0.024725
	5.0	0.52	0.6	0.01	0.425	0.221	0.00221
	5.6	0			0.3		
North Ditch Total					4.2	1.95275	1.38

Division Total 12.0 10.18 8.34
 Error -3.6%

Average Velocity = 0.82 ft/sec

River at—

Angle coef- ficient	Dist. from initial point	Width	Depth	Observa- tion depth	Rev- olu- tions	Time in sec- onds	VELOCITY		Adjusted for hor. angle or	Area	Discharge	
							At point	Mean in ver- tical				
REW	1.1	0.45	0.32	0.6	—	—	—	—		0.144	0.135	.80
	1.5	0.5	0.32	0.6	—	0.94				0.50	0.47	.85
	2.0	0.5	0.75	0.6	—	1.22				0.38	0.42	
	2.5	0.5	0.96	1	—	1.29				0.48	0.62	.90
	3.0	0.5	1.13	1	—	1.40				0.57	0.79	
	3.5	0.5	1.25	1	—	1.36				0.63	0.85	.92
	4.0	0.5	1.29	1	—	1.19				0.65	0.77	.94
	4.5	0.5	1.32	1	—	1.17				0.66	0.77	
	5.0	0.5	1.30	1	—	1.09				0.65	0.71	.96
	5.5	0.5	1.29	1	—	0.90				0.65	0.58	.97
	6.0	0.5	1.34	1	—	0.72				0.67	0.48	.98
	6.5	0.5	1.38	1	—	0.59				0.69	0.41	.99
	7.0	0.5	1.37	1	—	0.42				0.69	0.29	
	7.5	0.5	1.23	1	—	0.23				0.62	0.14	
o	8.0	0.7	0.11	1	—	0				0.78	0	1.00
	8.9	LEW	0		—						0.70	
NORTH DITCH												.99
	1.4	LEW			—							.98
	2.0	0.55	0.36	0.6	—	0.68				0.198	0.135	.97
	2.5	0.5	0.44	1	—	0.90				0.22	0.198	.96
	3.0	0.5	0.60	1	—	1.05				0.30	0.315	.94
	3.5	0.375	0.69	1	—	1.12				0.259	0.290	.92
	4.0	0.375	0.73	1	—	0.59				0.274	0.161	.90
	3.75	0.25	0.71	1	—	0.89				0.178	0.158	.88
	4.5	0.375	0.53	1	—	0.46				0.199	0.091	.86
	5.0	0.425	0.43	1	—	0.01				0.183	0.002	.84
	4.75	0.25	0.52	1	—	0.23				0.130	0.030	.82
	5.6	REW	0		—							.80
					—						1.4	