


MEMORANDUM

November 29, 2005

TO: Water District 130 2005 Annual File
Clear Springs Foods Snake River Farms Delivery Call File

FROM: Cindy Yenter, Watermaster 

RE: Repair of Clear Springs Foods Spillway Dam at Snake River Farm Diversion

On July 12, 2005 I made an inspection of the west spillway at the Snake River Farm spring collection structure feeding the 54-inch fresh water pipeline. This spillway was leaking approximately 2 cfs on May 5, 2005, when Brian Patton and I made a field investigation pursuant to Clear Springs' May 2, 2005 call for water.

The July 8, 2005 Order in response to the Snake River Farms call directed Clear Springs Foods to repair the leaky spillway so that all available flows were being diverted to the 54-inch pipeline.

On July 12, the spillway had been satisfactorily repaired. The wood stop logs in the spillway were replaced with a steel plate which was sealed with plastic sheeting. There was a very minor seep around the base of the plate, but no leaks, and no water flowed down the drainage toward Clear Lakes. All spring flows are now entering the collection channel leading to the fresh water pipeline.